

# Spokane Tribal Hatchery PRAS Implementation and Build

RFP25-002

## Addendum 3

Questions for Spokane Tribe of Indians

### **Section 13 99 60**

Part 2.2 – Microscreen Drum Filter

- Please add: *Supplied by PR Aqua*, after Hydrotech

Response: Comment is understood. This is covered in Part 2.2 L with the term “or equal”. No need to update and reissue the specification.

Part 2.5 – LHO-100

- What is the height of the LHO?
- How many orifices and of what size are the orifices on the LHO distribution plate.

Response: The height of the LHO and the number/size of the orifices are typically calculated by the manufacturer as each manufacturer will construct these slightly differently. This is a performance spec with design and operating criteria detailed in Section 2.5 A 1-4 and Table 2-4.

Part 2.8 – Ultraviolet Disinfecter

- Please approve that attached as an alternate manufacturer, UltraAqua - supplied by PR Aqua

Response: This is approved. We don't specify a specific vendor. We have federal funds involved for this project and there are certain rules for this. We typically list types, models, and state Or Equal. Not who the specific vendor/supplier is.